

Grand Fire Protection District No. 1

Knox Box Request

Grand Fire Protection District No. 1 requests all new commercial and multi-family habitation buildings including all buildings that have a fire alarm system or fire sprinkler system to purchase and install a knoxbox for fire department rapid entry.

Type of Knox Box

- 3200 series with hinged door
- Surface mount #3266
- Recessed mount #3275

Purpose

- Fire department rapid access
- Access after hours
- Maintain security of building master keys on premises
- Minimize damage to doors

Location

- Fire Marshall will give direction where to mount
- Exterior of building
- Adjacent to doors accessing fire alarm control panels
- Fire sprinkler rooms
- Five to six feet in height off of finish grade
- Within four to five feet off side of doors

Purchase of a Knox box

- Contact the Fire Marshall or Fire Chief for an Authorization Order Form